



EAST GREENWICH TOWNSHIP SCHOOL DISTRICT

Andrea Evans, Superintendent

Gregory Wilson, Business Administrator

December 18, 2024

Dear East Greenwich Township School District Community,

The East Greenwich Township School District is committed to protecting the health of the students, teachers, and staff members. To protect our community and be in compliance with the Department of Education regulations, the East Greenwich Township Schools' drinking water was tested for lead.

Water testing for lead in drinking water locations was conducted in both the Jeffrey Clark School and the Samuel Mickle School on November 16, 2024.

The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15.5 parts per billion (ppb). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountain bubblers and sinks, water bottle filling stations, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected nor designed to be used for water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet.

Of the 152 locations tested, 6 locations indicated results above the 15.5 parts per billion (ppb) action level. A summary of each location above the action level, as well as the short-term response, is found below:

Jeffrey Clark Elementary School

SAMPLE LOCATION	SAMPLE RESULT	SHORT TERM RESPONSE
Bubbler – Room 156	44.0 ppb	Taken out of service
Sink – Room 122	18.1 ppb	Taken out of service
Sink – Room 121	17.0 ppb	Taken out of service
Bubbler – Room 124	56.8 ppb	Taken out of service
Bubbler – Room 123	134 ppb	Taken out of service

Samuel Mickle Elementary School

SAMPLE LOCATION	SAMPLE RESULT	SHORT TERM RESPONSE
Sink – Child Study Team Office	16.9 ppb	Taken out of service



EAST GREENWICH TOWNSHIP SCHOOL DISTRICT

Andrea Evans, Superintendent

Gregory Wilson, Business Administrator

At this time, permanent solutions for each of these locations are being evaluated. The district will notify staff, students, and parents as these solutions are implemented. Questions regarding the sample locations can be directed to me by email, wilsong@eastgreenwich.k12.nj.us or by phone, 856-423-2958 x1002. Thank you for your continued support of the East Greenwich Township School District.

Sincerely,

Gregory Wilson
School Business Administrator