

**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Jeffrey Clark Elementary School
7 Quaker Road
Mickleton, NJ 08056


Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00
Date & Time Analyzed: 02/27/2017 15:12 - 17:07
Date & Time Analyzed: 02/28/2017 10:07 - 15:12
Date & Time Analyzed: 03/03/2017 13:29 - 15:08
Date & Time Analyzed: 03/14/2017 11:38 - 14:33
Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|---------------------------|------------|--------------|
| Field Reagent Blank (FRB) | <2.00 | 15.5 |
| CLK-KC-KITCH3 | <2.00 | 15.5 |
| CLK-KC-KITCH5 | 10.3 | 15.5 |
| CLK-KC-KITCH6 | 6.68 | 15.5 |
| CLK-WC-CAFE1 | <2.00 | 15.5 |
| CLK-DW-104 | 4.93 | 15.5 |
| CLK-DW-105 | 17.9 | 15.5 |
| CLK-DW-102 | <2.00 | 15.5 |
| CLK-DW-103 | 76.0 | 15.5 |
| CLK-DW-100 | <2.00 | 15.5 |
| CLK-DW-101 | <2.00 | 15.5 |
| CLK-SO-RR104 | <2.00 | 15.5 |
| CLK-SO-NURRR | 2.20 | 15.5 |
| CLK-SO-FACRR2 | <2.00 | 15.5 |
| CLK-SO-FACRR1 | <2.00 | 15.5 |
| CLK-NS-NURSE | <2.00 | 15.5 |
| CLK-SO-MNOFF | 5.29 | 15.5 |
| CLK-DW-166 | <2.00 | 15.5 |
| CLK-CS-166B | <2.00 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 856-875-3506 Phone
 856-875-3507 Fax

www.sjwaterest.com
 NJ DEP Certified Lab #08006

Jeffrey Clark Elementary School

7 Quaker Road
 Mickleton, NJ 08056


Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00
 Date & Time Analyzed: 02/27/2017 15:12 - 17:07
 Date & Time Analyzed: 02/28/2017 10:07 - 15:12
 Date & Time Analyzed: 03/03/2017 13:29 - 15:08
 Date & Time Analyzed: 03/14/2017 11:38 - 14:33
 Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|-----------------|------------|--------------|
| CLK-CS-166D | 7.39 | 15.5 |
| CLK-DW-165 | <2.00 | 15.5 |
| CLK-DW-164 | <2.00 | 15.5 |
| CLK-DW-163 | <2.00 | 15.5 |
| CLK-DW-161 | <2.00 | 15.5 |
| CLK-WC-HALL7 | <2.00 | 15.5 |
| CLK-SO-MRR159 | 2.67 | 15.5 |
| CLK-DW-159 | 24.0 | 15.5 |
| CLK-DW-156 | 8.88 | 15.5 |
| CLK-CS-157 | 4.40 | 15.5 |
| CLK-DW-155 | <2.00 | 15.5 |
| CLK-CS-155RR | <2.00 | 15.5 |
| CLK-DW-154 | 13.6 | 15.5 |
| CLK-DW-153 | 6.84 | 15.5 |
| CLK-CS-153RR | <2.00 | 15.5 |
| CLK-DW-152 | <2.00 | 15.5 |
| CLK-DW-151 | 3.36 | 15.5 |
| CLK-CS-151RR | <2.00 | 15.5 |
| CLK-DW-150 | 42.0 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Jeffrey Clark Elementary School

7 Quaker Road
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00

Date & Time Analyzed: 02/27/2017 15:12 - 17:07

Date & Time Analyzed: 02/28/2017 10:07 - 15:12


Date & Time Analyzed: 03/03/2017 13:29 - 15:08

Date & Time Analyzed: 03/14/2017 11:38 - 14:33

Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|-----------------|------------|--------------|
| CLK-CS-15ORR | <2.00 | 15.5 |
| CLK-WC-HALL2 | <2.00 | 15.5 |
| CLK-DW-114 | 8.22 | 15.5 |
| CLK-DW-116 | 3.87 | 15.5 |
| CLK-DW-115 | 4.36 | 15.5 |
| CLK-DW-118 | <2.00 | 15.5 |
| CLK-DW-117 | <2.00 | 15.5 |
| CLK-DW-120 | <2.00 | 15.5 |
| CLK-DW-119 | <2.00 | 15.5 |
| CLK-DW-122 | <2.00 | 15.5 |
| CLK-DW-121 | <2.00 | 15.5 |
| CLK-DW-124 | <2.00 | 15.5 |
| CLK-CS-124RR | 76.0 | 15.5 |
| CLK-DW-123 | 10.2 | 15.5 |
| CLK-DW-126 | 5.56 | 15.5 |
| CLK-DW-125 | <2.00 | 15.5 |
| CLK-DW-128 | <2.00 | 15.5 |
| CLK-DW-127 | <2.00 | 15.5 |
| CLK-DW-130 | <2.00 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterest.com
NJ DEP Certified Lab #08006

Jeffrey Clark Elementary School

7 Quaker Road
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00

Date & Time Analyzed: 02/27/2017 15:12 - 17:07

Date & Time Analyzed: 02/28/2017 10:07 - 15:12


Date & Time Analyzed: 03/03/2017 13:29 - 15:08

Date & Time Analyzed: 03/14/2017 11:38 - 14:33

Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|---------------------------|------------|--------------|
| CLK-DW-131 | <2.00 | 15.5 |
| CLK-WC-GYM1 | <2.00 | 15.5 |
| CLK-WC-HALL5 | <2.00 | 15.5 |
| CLK-SO-RR139B | <2.00 | 15.5 |
| CLK-DW-143 | <2.00 | 15.5 |
| CLK-DW-142 | <2.00 | 15.5 |
| CLK-DW-145 | <2.00 | 15.5 |
| CLK-DW-144 | <2.00 | 15.5 |
| CLK-DW-147 | <2.00 | 15.5 |
| CLK-DW-146 | <2.00 | 15.5 |
| CLK-DW-149 | <2.00 | 15.5 |
| CLK-DW-148 | <2.00 | 15.5 |
| Field Reagent Blank (FRB) | <2.00 | 15.5 |
| CLK-KC-KITCH1 | 2.14 | 15.5 |
| CLK-KC-KITCH2 | 4.25 | 15.5 |
| CLK-KC-KITCH4 | 13.7 | 15.5 |
| CLK-WC-CAFE2 | <2.00 | 15.5 |
| CLK-CS-104 | 2.79 | 15.5 |
| CLK-CS-105 | 2.61 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 856-875-3506 Phone
 856-875-3507 Fax

www.sjwaterfest.com
 NJ DEP Certified Lab #188006

Jeffrey Clark Elementary School

7 Quaker Road
 Mickleton, NJ 08056


Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00
 Date & Time Analyzed: 02/27/2017 15:12 - 17:07
 Date & Time Analyzed: 02/28/2017 10:07 - 15:12
 Date & Time Analyzed: 03/03/2017 13:29 - 15:08
 Date & Time Analyzed: 03/14/2017 11:38 - 14:33
 Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|-----------------|------------|--------------|
| CLK-CS-102 | 2.26 | 15.5 |
| CLK-CS-103 | 3.19 | 15.5 |
| CLK-CS-100 | 2.40 | 15.5 |
| CLK-CS-101 | 3.75 | 15.5 |
| CLK-SO-NRENRR | 2.53 | 15.5 |
| CLK-WC-HALL1 | <2.00 | 15.5 |
| CLK-SO-NUREXM | 5.20 | 15.5 |
| CLK-SO-MNOFRR | <2.00 | 15.5 |
| CLK-TL-FACUL | <2.00 | 15.5 |
| CLK-CS-166A | <2.00 | 15.5 |
| CS-166C | 6.52 | 15.5 |
| CLK-CS-166E | 23.3 | 15.5 |
| CLK-CS-165 | <2.00 | 15.5 |
| CLK-CS-164 | 2.17 | 15.5 |
| CLK-CS-163 | 2.03 | 15.5 |
| CLK-CS-161 | 3.94 | 15.5 |
| CLK-WC-HALL6 | <2.00 | 15.5 |
| CLK-SO-WRR159 | 3.91 | 15.5 |
| CLK-CS-159 | 24.8 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 856-875-3506 Phone
 856-875-3507 Fax

www.sjwatertest.com
 NJ DEP Certified Lab #08006

Jeffrey Clark Elementary School
 7 Quaker Road
 Mickleton, NJ 08056


Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00
 Date & Time Analyzed: 02/27/2017 15:12 - 17:07
 Date & Time Analyzed: 02/28/2017 10:07 - 15:12
 Date & Time Analyzed: 03/03/2017 13:29 - 15:08
 Date & Time Analyzed: 03/14/2017 11:38 - 14:33
 Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|-----------------|------------|--------------|
| CLK-CS-156 | 16.0 | 15.5 |
| CLK-CS-155 | <2.00 | 15.5 |
| CLK-CS-154 | 20.2 | 15.5 |
| CLK-CS-153 | 2.35 | 15.5 |
| CLK-CS-152 | 2.38 | 15.5 |
| CLK-CS-152RR | <2.00 | 15.5 |
| CLK-CS-151 | 38.0 | 15.5 |
| CLK-CS-150 | 40.0 | 15.5 |
| CLK-WC-HALL3 | <2.00 | 15.5 |
| CLK-CS-114 | 5.22 | 15.5 |
| CLK-CS-116 | 4.25 | 15.5 |
| CLK-CS-115 | 2.70 | 15.5 |
| CLK-CS-118 | <2.00 | 15.5 |
| CLK-CS-117 | <2.00 | 15.5 |
| CLK-CS-120 | <2.00 | 15.5 |
| CLK-CS-119 | 2.58 | 15.5 |
| CLK-CS-122 | <2.00 | 15.5 |
| CLK-CS-122RR | <2.00 | 15.5 |
| CLK-CS-121 | <2.00 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Jeffrey Clark Elementary School

7 Quaker Road
Mickleton, NJ 08056


Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00
Date & Time Analyzed: 02/27/2017 15:12 - 17:07
Date & Time Analyzed: 02/28/2017 10:07 - 15:12
Date & Time Analyzed: 03/03/2017 13:29 - 15:08
Date & Time Analyzed: 03/14/2017 11:38 - 14:33
Date & Time Analyzed: 03/15/2017 09:21 - 13:03

| Sample Location | First Draw | Action Level |
|-----------------|------------|--------------|
| CLK-CS-121RR | <2.00 | 15.5 |
| CLK-CS-124 | 2.00 | 15.5 |
| CLK-CS-123 | <2.00 | 15.5 |
| CLK-CS-123RR | <2.00 | 15.5 |
| CLK-CS-126RR | <2.00 | 15.5 |
| CLK-CS-126 | <2.00 | 15.5 |
| CLK-CS-125 | 2.01 | 15.5 |
| CLK-CS-125RR | <2.00 | 15.5 |
| CLK-CS-128 | <2.00 | 15.5 |
| CLK-CS-128RR | <2.00 | 15.5 |
| CLK-CS-127 | <2.00 | 15.5 |
| CLK-CS-127RR | 5.23 | 15.5 |
| CLK-CS-130 | <2.00 | 15.5 |
| CLK-CS-130RR | <2.00 | 15.5 |
| CLK-CS-131 | <2.00 | 15.5 |
| CLK-CS-131RR | <2.00 | 15.5 |
| CLK-WC-GYM2 | <2.00 | 15.5 |
| CLK-WC-HALL4 | <2.00 | 15.5 |
| CLK-SO-RR139A | <2.00 | 15.5 |

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08096

Jeffrey Clark Elementary School

7 Quaker Road
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/22/2017 05:00 - 06:38

Date & Time Analyzed: 02/24/2017 14:15 - 17:00

Date & Time Analyzed: 02/27/2017 15:12 - 17:07

Date & Time Analyzed: 02/28/2017 10:07 - 15:12

Date & Time Analyzed: 03/03/2017 13:29 - 15:08

Date & Time Analyzed: 03/14/2017 11:38 - 14:33

Date & Time Analyzed: 03/15/2017 09:21 - 13:03


| Sample Location | First Draw | Action Level |
|-----------------|------------|--------------|
| CLK-CS-143 | 4.17 | 15.5 |
| CLK-CS-142 | 4.71 | 15.5 |
| CLK-CS-145 | <2.00 | 15.5 |
| CLK-CS-144 | <2.00 | 15.5 |
| CLK-CS-147 | <2.00 | 15.5 |
| CLK-CS-146 | <2.00 | 15.5 |
| CLK-CS-149 | <2.00 | 15.5 |
| CLK-CS-148 | <2.00 | 15.5 |

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

3/17/17
Date