

**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08066

Samuel Mickle School

559 Kings Highway
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/23/2017 05:06 - 06:46


Date & Time Analyzed: 03/15/2017 13:09 - 15:07

Date & Time Analyzed: 03/16/2017 09:29 - 16:10

Date & Time Analyzed: 03/17/2017 09:28 - 13:04

Sample Location	First Draw	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MICK-SO-MENKIT	<2.00	15.5
MICK-SO-WOMKIT	<2.00	15.5
MICK-DW-PREKIT	9.50	15.5
MICK-SO-PREKIT	3.70	15.5
MICK-KC-KITCH1	<2.00	15.5
MICK-KC-KITCH2	<2.00	15.5
MICK-KE-KITCH	<2.00	15.5
MICK-KC-KITCH3	<2.00	15.5
MICK-KC-KITCH5L	<2.00	15.5
MICK-KC-KITCH5R	<2.00	15.5
MICK-SP-KITCH	<2.00	15.5
MICK-WC-CAFÉ	<2.00	15.5
MICK-TL-FAKIT	<2.00	15.5
MICK-DW-309	<2.00	15.5
MICK-CS-309	<2.00	15.5
MICK-SO-MENFAC	<2.00	15.5
MICK-SO-WOMFAC	2.23	15.5
MICK-DW-307	2.59	15.5
MICK-CS-307	2.14	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 856-875-3506 Phone
 856-875-3507 Fax

www.sjwatertest.com
 NJ DEP Certified Lab #08006

Samuel Mickle School

559 Kings Highway
 Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/23/2017 05:06 - 06:46


Date & Time Analyzed: 03/15/2017 13:09 - 15:07

Date & Time Analyzed: 03/16/2017 09:29 - 16:10

Date & Time Analyzed: 03/17/2017 09:28 - 13:04

Sample Location	First Draw	Action Level
MICK-DW-304	17.5	15.5
MICK-CS-304	4.03	15.5
MICK-WC-HALL1	<2.00	15.5
MICK-WC-HALL2	<2.00	15.5
MICK-CS-400	<2.00	15.5
MICK-CS-402	<2.00	15.5
MICK-CS-403	<2.00	15.5
MICK-CS-404	<2.00	15.5
MICK-CS-407	<2.00	15.5
MICK-CS-406	<2.00	15.5
MICK-CS-409	3.36	15.5
MICK-CS-408	<2.00	15.5
MICK-WC-HALL8	<2.00	15.5
MICK-WC-HALL7	<2.00	15.5
MICK-SO-MEN419	<2.00	15.5
MICK-SO-WOM419	<2.00	15.5
MICK-DW-303	<2.00	15.5
MICK-CS-303	4.37	15.5
MICK-DW-302	<2.00	15.5
MICK-CS-302	2.61	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**
 4077 South Black Horse Pike
 Williamstown, NJ 08094
 856-875-3506 Phone
 856-875-3507 Fax

www.sjwatertest.com
 NJ DEP Certified Lab #080906

Samuel Mickle School

559 Kings Highway
 Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/23/2017 05:06 - 06:46


Date & Time Analyzed: 03/15/2017 13:09 - 15:07

Date & Time Analyzed: 03/16/2017 09:29 - 16:10

Date & Time Analyzed: 03/17/2017 09:28 - 13:04

Sample Location	First Draw	Action Level
MICK-DW-301	<2.00	15.5
MICK-CS-301	3.28	15.5
MICK-DW-300	<2.00	15.5
MICK-CS-300	2.34	15.5
MICK-DW-CSTUDY	11.4	15.5
MICK-CS-CSTUDY	<2.00	15.5
MICK-SO-MEDWK	7.50	15.5
MICK-NS-NURSE	<2.00	15.5
MICK-WC-HALL6	<2.00	15.5
MICK-SO-ADKIT	2.25	15.5
MICK-WC-LOBBY	<2.00	15.5
MICK-SO-TCHWK	<2.00	15.5
MICK-SO-MNOFRR	<2.00	15.5
MICK-SO-PRINRR	3.16	15.5
MICK-DW-167	<2.00	15.5
MICK-CS-167	<2.00	15.5
MICK-CS-167STR	<2.00	15.5
MICK-DW-101	<2.00	
MICK-CS-101	9.38	15.5
MICK-DW-100	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwaterfest.com
NJ DEP Certified Lab #08906

Samuel Mickle School

559 Kings Highway
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/23/2017 05:06 - 06:46


Date & Time Analyzed: 03/15/2017 13:09 - 15:07

Date & Time Analyzed: 03/16/2017 09:29 - 16:10

Date & Time Analyzed: 03/17/2017 09:28 - 13:04

Sample Location	First Draw	Action Level
MICK-CS-100	2.03	15.5
MICK-DW-103	26.0	15.5
MICK-CS-103	2.89	15.5
MICK-DW-102	<2.00	15.5
MICK-CS-102	8.18	15.5
MICK-SO-MEN103	<2.00	15.5
MICK-SO-WOM103	<2.00	15.5
MICK-WC-HALL3	<2.00	15.5
MICK-WC-HALL4	<2.00	15.5
MICK-CS-200	<2.00	15.5
MICK-CS-202	2.68	15.5
MICK-CS-204	<2.00	15.5
MICK-CS-205	<2.00	15.5
MICK-CS-206	<2.00	15.5
MICK-CS-207	<2.00	15.5
MICK-DW-107	<2.00	15.5
MICK-CS-107	3.27	15.5
MICK-DW-104	<2.00	15.5
MICK-CS-104	<2.00	15.5
MICK-DW-109	<2.00	15.5

Units - ug/L = ppb



**South Jersey
Water Test, LLC**

4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Samuel Mickle School

559 Kings Highway
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time First Draw Sampled: 02/23/2017 05:06 - 06:46

Date & Time Analyzed: 03/15/2017 13:09 - 15:07

Date & Time Analyzed: 03/16/2017 09:29 - 16:10

Date & Time Analyzed: 03/17/2017 09:28 - 13:04


Sample Location	First Draw	Action Level
MICK-CS-109	3.19	15.5
MICK-DW-106	<2.00	15.5
MICK-CS-106	<2.00	15.5
MICK-WC-HALL5	<2.00	15.5
MICK-SO-MENGYM	<2.00	15.5
MICK-SO-WOMGYM	<2.00	15.5
MICK-WC-GYM	<2.00	15.5
MICK-SO-GYMTCH	2.22	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.


Mark J. Riether, Laboratory Director

3/20/17
Date