

**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Jeffrey Clark Elementary School

7 Quaker Road  
Mickleton, NJ 08056

### Results of Lead Analysis

Date & Time Sampled: 03/24/2017 05:02 - 05:32


Date & Time Analyzed: 03/27/2017 19:05 - 22:14

Date & Time Analyzed: 03/28/2017 11:10 - 13:47

Date & Time Analyzed: 03/30/2017 24:20

| Sample Location           | Sample Result | Action Level |
|---------------------------|---------------|--------------|
| Field Reagent Blank (FRB) | <2.00         | 15.5         |
| CLK-DW-105                | 34.2          | 15.5         |
| CLK-DW-105 (Flushed)      | <2.00         | 15.5         |
| CLK-DW-103                | 247           | 15.5         |
| CLK-DW-103 (Flushed)      | 83.0          | 15.5         |
| CLK-CS-166E               | 11.7          | 15.5         |
| CLK-CS-166E (Flushed)     | <2.00         | 15.5         |
| CLK-DW-159                | 37.3          | 15.5         |
| CLK-DW-159 (Flushed)      | 7.30          | 15.5         |
| CLK-CS-159                | 39.3          | 15.5         |
| CLK-CS-159 (Flushed)      | 29.2          | 15.5         |
| CLK-CS-156                | 25.5          | 15.5         |
| CLK-CS-156 (Flushed)      | <2.00         | 15.5         |
| CLK-CS-154                | 9.65          | 15.5         |
| CLK-CS-154 (Flushed)      | <2.00         | 15.5         |
| CLK-CS-151                | 6.30          | 15.5         |
| CLK-CS-151 (Flushed)      | <2.00         | 15.5         |
| CLK-DW-150                | 14.8          | 15.5         |
| CLK-DW-150 (Flushed)      | 9.62          | 15.5         |
| CLK-CS-150                | <2.00         | 15.5         |

Units - ug/L = ppb



**South Jersey  
Water Test, LLC**  
4077 South Black Horse Pike  
Williamstown, NJ 08094  
856-875-3506 Phone  
856-875-3507 Fax

www.sjwatertest.com  
NJ DEP Certified Lab #08006

## Jeffrey Clark Elementary School

7 Quaker Road  
Mickleton, NJ 08056

### Results of Lead Analysis

Date & Time Sampled: 03/24/2017 05:02 - 05:32

Date & Time Analyzed: 03/27/2017 19:05 - 22:14

Date & Time Analyzed: 03/28/2017 11:10 - 13:47

Date & Time Analyzed: 03/30/2017 24:20


| Sample Location        | Sample Result | Action Level |
|------------------------|---------------|--------------|
| CLK--CS-150 (Flushed)  | <2.00         | 15.5         |
| CLK-CS-124RR           | 2.69          | 15.5         |
| CLK-CS-124RR (Flushed) | <2.00         | 15.5         |

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.

Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

  
Mark J. Riether, Laboratory Director

4/3/17  
Date