



**South Jersey
Water Test, LLC**
4077 South Black Horse Pike
Williamstown, NJ 08094
856-875-3506 Phone
856-875-3507 Fax

www.sjwatertest.com
NJ DEP Certified Lab #08006

Samuel Mickle School

559 Kings Highway
Mickleton, NJ 08056

Results of Lead Analysis

Date & Time Sampled: 03/24/2017 05:38 - 05:43

Date & Time Analyzed: 03/28/2017 13:00 - 14:22

Sample Location	Sample Result	Action Level
Field Reagent Blank (FRB)	<2.00	15.5
MICK-DW-304	3.26	15.5
MICK-DW-304 (Flushed)	<2.00	15.5
MICK-DW-103	14.8	15.5
MICK-DW-103 (Flushed)	<2.00	15.5

Units - ug/L = ppb

Action Level: The concentration of lead which determines whether some form of corrective action may be necessary.

QA/QC: Laboratory Fortified Blank (LFB) meets criteria of plus or minus 15% recovery.
Field Reagent Blank (FRB) concentration equals <2.00 ug/L.

Mark J. Riether, Laboratory Director

4/6/17
Date