

EAST GREENWICH TOWNSHIP SCHOOL DISTRICT

SAMUEL MICKLE BUILDING, 559 KINGS HIGHWAY, MICKLETON, NJ 08056

PHONE: 856-423-0412

FAX: 856-224-0144

Dr. James J. Lynch, Superintendent
Gregory Wilson, Business Administrator

Lyn McGravey, President of the Board of Education
Dr. Kimberley Chiodi, Director of Curriculum & Instruction

April 7, 2017

Dear East Greenwich Township School District Community,

On March 24, 2017, the East Greenwich Township School District conducted a second round of lead testing of all the drinking water outlets and classroom sinks within the District that originally tested over the lead action level of 15.5 parts per billion (PPB). The original test was conducted on February 22 & 23, 2017.

The table below identifies the drinking water outlets that tested above the 15.5 parts per billion (PPB) for lead during the March 24th test, the actual lead level, and what remedial action the East Greenwich Township School District has taken to reduce the levels of lead at these locations. The 15.5 parts per billion action level is established by the Environmental Protection Agency.

Sample Location	First Draw Results in PPB	Flushed Draw Results in PPB	Remedial Action
Clark Classroom 105 Bubbler	34.2	Less than 2.0	Disconnected outlet and bottled water provided. Fountain will be replaced.
Clark Classroom 103 Bubbler	247.0	83.0	Disconnected outlet and bottled water provided. Fountain will be replaced.
Clark Classroom 159 Bubbler	37.3	7.3	Disconnected outlet and bottled water provided. Fountain will be replaced.

The table below identifies the classroom sinks that tested above the 15.5 parts per billion (PPB) for lead during the March 24th test, the actual lead level, and what remedial action the East Greenwich Township School District has taken to reduce the levels of lead at these locations.

Sample Location	First Draw Results in PPB	Flushed Draw Results in PPB	Remedial Action
Clark Classroom 159 Sink	39.3	29.2	Sink designated as hand washing only
Clark Classroom 156 Sink	25.5	Less than 2.0	Sink designated as hand washing only

All drinking water outlets that have tested above the lead action level will be replaced and then re-tested to ensure the safety of the water. A complete copy of the test results are available for review on the East Greenwich Township School District website at <http://www.eastgreenwich.k12.nj.us>.

JESSICA G. MAHONEY
 Jeffrey Clark School Principal
 (856) 423-0613 ext. 1020
 (856) 423-9186 -Fax

KAROLYN MASON
 District Assistant Principal
 (856) 423-0412 ext. 1080
 (856) 224-0144-Fax


BETH ANN GODFREY
 Child Study Team Supervisor
 (856) 423-0412 ext. 1039
 (856) 423-8116 - Fax

ANDREA EVANS
 Samuel Mickle School Principal
 (856) 423-0412 ext. 1040
 (856) 224-0144 -Fax

For more information on reducing lead exposure around your home and the health effects of lead, visit the EPA's website at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your healthcare provider.

Thank you for your continued support of the East Greenwich Township School District.

Sincerely,



Gregory Wilson
School Business Administrator

JESSICA G. MAHONEY
Jeffrey Clark School Principal
(856) 423-0613 ext. 1020
(856) 423-9186 -Fax

KAROLYN MASON
District Assistant Principal
(856) 423-0412 ext. 1080
(856) 224-0144-Fax

BETH ANN GODFREY
Child Study Team Supervisor
(856) 423-0412 ext. 1039
(856) 423-8116 - Fax

ANDREA EVANS
Samuel Mickle School Principal
(856) 423-0412 ext. 1040
(856) 224-0144 -Fax